

# ASHRAE Distinguished Lecturer Talk

ASHRAE India Chapter

New Delhi

18 June 2014

## Ventilation, IAQ and Energy Issues in hot humid climates – Past, Present and Future

Chandra Sekhar


Professor, PhD, Fellow ASHRAE, Fellow ISIAQ  
Department of Building, School of Design and Environment



**NUS**  
National University  
of Singapore

# **Learning Objectives**

- 1. Describe an integrated IAQ-Energy audit methodology**
- 2. Interpret the IAQ and Energy audit data from case studies in a hot and humid climate**
- 3. Describe the key features of Thermal Comfort and Ventilation Standards (a) ASHRAE Standards 55 & 62.1 and (b) Singapore Standards**
- 4. Describe the Singapore Green Mark Scheme for rating buildings for environmental sustainability**



# IAQ Scenario



Mendell, M.J., W.J. Fisk, K. Kreiss, H. Levin, D. Alexander, W.S. Cain, J.R. Girman, C.J. Hines, P.A. Jensen, D.K. Milton, L.P. Rexroat and K.M. Wallingford, 2002. Improving the health of workers in indoor environments: Priority research needs for a national occupational research agenda. American Journal of Public Health, Vol 92, No.9, 1430 -1440.

*..... improving building environments may result in health benefits for more than 15 million of the 89 million US indoor workers, with estimated economic benefits of \$5 to \$75 billion annually.*

***Fisk, W. J., Black, D. and Brunner, G. (2011), Benefits and costs of improved IEQ in U.S. offices. Indoor Air, 21, Issue 5 : 357–367***

Benefits and costs of improved IEQ in U.S. offices

### **Scenarios**

- Increasing vent rates when below 10 or 15 l/s per person
- Adding O/A economisers and controls when absent
- Eliminating winter indoor temps >23°C
- Reducing dampness and mold problems

### **Estimated Benefits**


- Increased work performance
- Reduced SBS symptoms
- Reduced absenteeism
- Improved thermal comfort for millions of office workers

Combined potential annual economic benefit of a set of nonoverlapping scenarios ≈\$20 billion

**Quantitative estimates have a high uncertainty  
– BUT opportunity for substantial benefits is clear**

# IAQ - Source Control


**“If there is a pile of manure in a space, do not try to remove the odor by ventilation. Remove the pile of manure.”**



**Max Joseph von Pettenkofer  
(1818-1901), german chemist**

# IAQ Audit - CASE STUDIES

# IAQ Audit




# OBJECTIVES OF AUDIT

- Establish status of Indoor Air Quality (IAQ)
- Identify strategies for improving IAQ
- Basis for developing an IAQ audit and management program

## Sick Building Syndrome


Figure 11 : A comparison of MALE and FEMALE Building Related Symptoms (Mean of all five buildings) - Here and Now (%)




Sekhar SC, KW Tham and KWD Cheong, Indoor Air Quality And Energy Performance of Air-conditioned Office Buildings In Singapore, Indoor Air - International Journal of Indoor Air Quality and Climate, 2003, Volume 13, Issue 4, pp. 315-331.

# Acceptability of Indoor Air Quality (% Dissatisfied)

## - A Comparison of Singapore and EU studies







**Figure7 : Indoor air acceptability versus thermal comfort**





Figure 9 : Indoor air acceptability versus stuffiness




# **DIMENSIONS OF INDOOR AIR QUALITY**

- Chemical
- Biological
- Physical


# CHEMICAL

- Sources
  - Interior furnishings
  - Equipment
  - Stationery
  - Outside sources
- Particular chemicals
  - TVOCs
  - Formaldehyde
  - Carbon Monoxide
  - Carbon Dioxide



# BIOLOGICAL

- Sources
  - Occupants
  - Visitors
  - Food
  - Outside sources
- Particular contaminants
  - Total Bacteria
  - Yeasts & Molds



# **VENTILATION STUDIES IN NINE AIR-CONDITIONED OFFICE BUILDINGS IN SINGAPORE**

**Period of Study : 1993 - 1997**

## **Factors affecting ventilation performance**

- **space layout**
- **fresh air quantity**
- **supply diffusers and return grilles**

## **Indoor air flow pattern**

- **Short circuiting**
- **Piston flow**
- **Perfect mixing**

## **Flow pattern affects**

- **Indoor Air Quality (IAQ)**
- **Building energy consumption**

# VENTILATION CHARACTERISTICS

## THE VENTILATION MODEL

### Age-of-air

Laverage amount of time elapsed since molecules in a sample entered the building

- measured by tracer gas techniques

**"youngest" air found where the outdoor air comes into the room –**

**"oldest" air found at any other point in the room**



# Tracer Gas Monitoring

- **TRACER GAS MEASUREMENTS**
- **AGE OF AIR VALUES**
  - **LOCAL MEAN AGE OF AIR**
  - **ROOM AVERAGE AGE OF AIR**
- **AIR CHANGE RATE**
- **Air Exchange Effectiveness (also known as Ventilation Effectiveness)**

type of tracers used usually colourless,  
odourless, inert gases (e.g. SF<sub>6</sub>)

Important aspect of TG measurements  
can be made in occupied buildings




# Concentration-decay method

Air Change per Hour (ACH)




slope of the tracer gas concentration decay curve

Linear Plot



Semi Log Plot



# Air Exchange Effectiveness

**Perfectly mixed air - datum for all three AEE parameters**

$$\text{AEE} = 1$$

$$\text{AEE}_G = 2.0$$

**"perfect" displacement flow**

$$\text{AEE}_G < 1.0$$

**shortcircuiting**

$$\text{AEE}_G > 1.0$$

**displacement flow**

**the greater the deviations from unity,  
more pronounced are the two flow patterns**

# Key building characteristics

**Floor by Floor AHUs  
CAV system**

**A, C**


**Floor by Floor AHUs  
VAV system**

**B, D, E,  
BB, DD, EE**


**3 Central AHUs  
VAV system**

**CC**

**Figure 1 : Summary of Air Change per Hour (ACH) values**




**Figure 2 : Comparison of fresh air provision  
based on design occupancy**





# Figure 5 : Comparison of Localised Air Exchange Effectiveness (AEEL) Values




# Conclusions – 9 Buildings Study

- **Tracer gas analysis : In-situ ventilation measurements**
- **Significant variations in ACH values**
- **Minor short-circuiting profiles in some zones**
- **AEE values generally indicative of well-mixed flow patterns**

## Causes


## Pollutants

## Recommendations



# **Some other Observations**


Zuraimi MS, Roulet C-A, Tham KW, Sekhar SC, David Cheong KW, Wong NH & Lee HK, 2004. "A comparative study of VOCs in Singapore and European Office Buildings", Building and Environment, Volume 41, Issue 3, March 2006, Pages 316-329




**Air change rates (ACH) measured in the European and Singapore buildings studied**

# **VENTILATION & IAQ ISSUES IN SPLIT SYSTEM AIR-CONDITIONING UNIT IN A RESIDENTIAL BUILDING IN SINGAPORE**

**Year of study : 2002/2003**



Master Bed-room in a condominium apartment (8<sup>th</sup> Storey)



CO<sub>2</sub> concentration during measurement and night-time sleeping periods<sup>36</sup>



# Thermal Comfort

## Ventilation

*and*

## IAQ

# Standards

**Current version –  
ASHRAE Standard  
55-2013**

**STANDARD**



**ANSI/ASHRAE Standard 55-2010**

(Supersedes ANSI/ASHRAE Standard 55-2004)

Includes ANSI/ASHRAE addenda listed in Appendix I

# **Thermal Environmental Conditions for Human Occupancy**

See Appendix I for approval dates by the ASHRAE Standards Committee, the ASHRAE Board of Directors, and the American National Standards Institute.


This standard is under continuous maintenance by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. The change submittal form, instructions, and deadlines may be obtained in electronic form from the ASHRAE Web site ([www.ashrae.org](http://www.ashrae.org)) or in paper form from the Manager of Standards. The latest edition of an ASHRAE Standard may be purchased from the ASHRAE Web site ([www.ashrae.org](http://www.ashrae.org)) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: [orders@ashrae.org](mailto:orders@ashrae.org). Fax: 404-321-5478. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to [www.ashrae.org/permissions](http://www.ashrae.org/permissions).

© 2010 ASHRAE


ISSN 1041-2336




**SSPC 55 to maintain and revise Standard 55. Standard on continuous maintenance. Standard 55 placed on continuous maintenance January 24, 2004 (Anaheim). SSPC 55 authorized 1/26/1994.**



ASHRAE Standard 55-2010





**Figure 5.2.1.2 Predicted percentage dissatisfied (PPD) as a function of predicted mean vote (PMV).**




Occupant  
controlled NV  
spaces

Adaptive model – global  
database of 21,000 meas –  
primarily in office buildings

No  
mechanical  
cooling  
system

No  
humidity or  
air speed  
limits  
required



Allows for  
local  
thermal  
discomfort  
in typical  
buildings

Figure 5.3 Acceptable operative temperature ranges for naturally conditioned spaces.

Operable windows –  
open to outdoors

Accounts for  
people's clothing  
adaptation in NV  
spaces

Mech Vent with  
unconditioned air  
possible<sup>42</sup>



**ANSI/ASHRAE Standard 62.1-2013**  
(Supersedes ANSI/ASHRAE Standard 62.1-2010)  
Includes ANSI/ASHRAE addenda listed in Appendix J

# Ventilation for Acceptable Indoor Air Quality

See Appendix J for approval dates by the ASHRAE Standards Committee, the ASHRAE Board of Directors, and the American National Standards Institute.

This standard is under continuous maintenance by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. The change submittal form, instructions, and deadlines may be obtained in electronic form from the ASHRAE website ([www.ashrae.org](http://www.ashrae.org)) or in paper form from the Manager of Standards. The latest edition of an ASHRAE Standard may be purchased from the ASHRAE Web site ([www.ashrae.org](http://www.ashrae.org)) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: [orders@ashrae.org](mailto:orders@ashrae.org). Fax: 404-321-5478. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to [www.ashrae.org/permissions](http://www.ashrae.org/permissions).

© 2013 ASHRAE

ISSN 1041-2336



# ASHRAE Standard 62.1

VRP


- Prescribes rates & procedures based on typical space contaminant sources & source strengths

IAQP


- Requires calculation of rates based on analysis of contaminant sources, concentration targets and perceived air quality targets.







air in which there are no known  
contaminants at harmful  
concentrations as determined by  
*cognizant authorities* and with which  
a substantial majority (80% or more)  
of the people exposed do not  
express dissatisfaction



**Acceptable  
Indoor Air  
Quality**

# Green Building Standard

- Published in January 2010
- Serves as benchmark for sustainable green buildings – does not apply to all buildings
- Addresses energy, impact on the atmosphere, sustainable sites, water use, materials and resources and IEQ
- Jurisdictional compliance option for International Green Construction Code

[www.ashrae.org/greenstandard](http://www.ashrae.org/greenstandard)



# Standard 189.1

- Standard for Design of High-Performance Green Buildings
- An ANSI standard developed in model code language
- Provides minimum requirements for high-performance, green building



# Standard 189.1 Topic Areas

SS

Sustainable Sites

WE

Water Use Efficiency

EE

Energy Efficiency

IEQ

Indoor Environmental Quality

MR

Building's Impact on the Atmosphere,  
Materials & Resources

CO

Construction and Operations Plans

# SINGAPORE

***SS 553 : 2009 Code of Practice for  
Air-conditioning and Mechanical  
Ventilation in Buildings (formerly CP 13)***

***SS 554 : 2009 Code of Practice for  
Indoor Air Quality for  
Air-Conditioned Buildings***

Table 1 – Outdoor air supply requirement for comfort air-conditioning



Type of building/ Occupancy	Minimum outdoor air supply			Air Class <sup>1</sup>
	L/s per m <sup>2</sup> floor area	m <sup>3</sup> /h per m <sup>2</sup> floor area	l/s per person	
Restaurants	3.4	12.2	5.1	2
(i) Dance halls	7.0	25.0	10.5	1
Offices	0.6	2.0	5.5	1
(ii) Shops, supermarkets and department stores	1.1	3.8	5.5	1 or 2
Theatres and cinemas seating area	2.0	7.3	3.0	1
Lobbies and corridors	0.3	1.1	3.3	1
Concourses	1.1	4.0	3.3	1
(iii) Hotel guest rooms	15.0L/s per room	54.0 m <sup>3</sup> /h per room	5.5	1
(iv) Classrooms				
Primary school children and above	2.8	10.0	4.2	1
Childcare Centres	2.8	10.0	8.4	1

ASHRAE Std 62.1-2010 (l/s/person)
5.1
10.3
8.5
7.8/7.6/7.8
2.7
2.7
3.5
5.5
4 – 7.4
8.6 <small>51</small>

# Energy Scenario



# World Marketed Energy Consumption by Region, 2004-2030



## OECD and Non-OECD Commercial Sector Delivered Energy Consumption, 2004-2030

**Commercial and Services sectors – includes different building types**

- Office buildings, schools, stores, correctional institutions, restaurants, hotels, hospitals, museums, banks, stadium**

Sources : 2004 – EIA, International Energy Annual 2004 (May-July 2006),  
Projections – EIA, System for the Analysis of Global Energy Markets (2007)



# BCA Green Mark Scheme Singapore

BCA GREEN MARK

## New Buildings

- New Dev
- Redevelopment
- A&A to existing buildings
- Major retrofitting

## Existing Buildings

- Under operation with no significant retrofitting works

**Green Mark  
Assessment  
Criteria**

# Points for Green Mark Criteria

## BCA Green Mark for Non-Residential Building Version 4.1

*15 January 2013*



BCA GREEN MARK

[http://www.bca.gov.sg/GreenMark/green\\_mark\\_criteria.html](http://www.bca.gov.sg/GreenMark/green_mark_criteria.html)

BCA Green Mark Schemes	Description	Effective Date
Non-Residential New Buildings (Version 4.1)	Applicable for new buildings such as offices, commercial, industrial and institutional buildings with or without air-conditioning systems.	15 Jan 2013 onwards
Residential New buildings (Version 4.1)	For new private and public residential developments.	15 Jan 2013 onwards
Existing Buildings (Version 3)	Applicable to existing commercial, industrial and institutional buildings under operation.	26 Jul 2012 onwards
Existing Buildings (Version 2.1)	Applicable to existing commercial, industrial and institutional buildings under operation. Assessment by this criteria is necessary for application of GMIS (Existing Building).	1 Dec 2009 onwards
Existing Residential Buildings (Version 1)	For existing private and public residential developments.	19 May 2011 onwards
Existing Schools (Version 1)	Applicable to MOE main stream schools (excluding International schools, Universities and Institute of Higher Learning: Polytechnics and ITE).	4 Aug 2011 onwards
Office Interior (Version 1.1)	Applicable for tenant renovation and maintenance practices.	01 Nov 2012 onwards
Landed Houses (Version 1)	For landed housing projects.	27 May 2009 onwards
Infrastructure (Version 1)	For infrastructure projects e.g. as barrages, roads, bridges.	27 May 2009 onwards
District (Version 2)	For district projects.	01 Jan 2013 onwards
Restaurants (Version 1)	For Restaurants.	12 Sep 2011 onwards
Supermarket (Version 1)	For Supermarket.	11 Oct 2012 onwards
Existing Data Centres (Version 1)	For Existing Data Centres.	11 Oct 2012 onwards
Retail (Version 1)	For Retail Tenants.	11 Oct 2012 onwards
New Parks (Version 1)	For New Parks	26 May 2010 onwards
Existing Parks (Version 1)	For Existing Parks	22 May 2008 onwards

# Green Mark Award Rating

Version NRB 4.1, 15 Jan 2013

## Green Mark Points

## Green Mark Rating

90 and above

**Green Mark Platinum**  
GMIS Req → Energy Modeling →  
At least **30%** Energy Savings

85 to < 90

**Green Mark Gold<sup>PLUS</sup>**  
GMIS Req → Energy Modeling →  
At least **25%** Energy Savings

75 to < 85

**Green Mark Gold**


50 to < 75


**Green Mark Certified**

# Green Mark Building Projects in Singapore (Cumulative)

Number of  
building projects

GFA  
(million m<sup>2</sup>)





## PERCENTAGE OF GREEN BUILDINGS IN SINGAPORE





- 16-storey state-of-the-art library with a 3-level basement
- two blocks - library collections - space for other public activities
- a 618-seat theatre
- owner's commitment at conceptualisation stage - design considerations : impact on environment, energy and water efficiency.
- Computer simulation & modeling - to find the best bldg orientation & confign - buffer from direct solar heat & optimising natural vent & daylighting.
- passive design solutions with env-friendly technologies

## KEY GREEN FEATURES

- Building orientated away from the E-W sun - sun shading features west face of building
- Energy efficient features - daylight sensors with automatic blinds at the building facades, motion sensors & energy efficient lightings
- An open plaza area between the two blocks - allows natural ventilation and daylighting
- Extensive landscaping, sky terraces and roof gardens - to lower local ambient temp
- Rain sensor - part of the automatic irrigation system for rooftop gardens. Water efficient taps & cisterns used to conserve water



# Zero Energy Building @ BCA Academy

(Special Buildings)

2010

Green Mark Platinum



## Key Features:

- Estimated energy savings: 388,720 kWh/yr
- Estimated water savings: 3,620 m<sup>3</sup>/yr
- ETTV: 43.79 W/m<sup>2</sup>

## Key Features:

- Sunshading devices and efficient glazing.
- ACMV System (high performance chillers, displacement ventilation, personalised ventilation, under-floor air distribution system).
- Photovoltaic Technology of 190kWp capacity.
- Solar assisted stack ventilation.
- Mirror ducts, light pipes and light shelves.
- Sensors and monitoring system for all rooms.

PLATINUM

BCA  
**GREEN MARK FOR  
BUILDINGS AWARD**

## **Carlton City Hotel Singapore**

New Non-Residential Buildings

**Client / Developer**

Carlton Properties (Singapore)  
Pte. Ltd.

**Project Manager**

KPK Quantity Surveyors  
(Singapore) Pte Ltd

**Architect**

DP Architects Pte Ltd

**M&E Engineer**

Beca Carter Hollings & Ferner  
(S.E.Asia) Pte Ltd

**Structural Engineer**

T.Y.Lin International Pte Ltd

**Quantity Surveyor**

KPK Quantity Surveyors  
(Singapore) Pte Ltd

**Main Contractor**

Kajima Overseas Asia Pte Ltd

**Landscape Consultant**

Site Concepts  
International Pte Ltd

**Lighting Consultant**

The Lightbox Pte Ltd

**Interior Designer**

Hirsch / Bedner Associates  
Pte Ltd

**Façade Consultant**

Aurecon Singapore (Pte.) Ltd.

**ACMV Contractor**

Shinryo Corporation  
(Singapore Branch)

**A/V Consultant**

Acvicon Acoustics Consultants  
Pte Ltd

**Sign & Way Finding  
Strategy Consultant**

Design Datum Pte Ltd

**ESD Consultant**

Kaer Pte Ltd

**Key Features**

- Estimated energy savings: 3,653,132 kWh/yr; estimated water savings: 12,800 m<sup>3</sup>/yr; ETTV: 31.41 W/m<sup>2</sup>.
- Chiller plant system efficiency of  $\leq 0.65\text{kW/ton}$ .
- Extensive use of LED lighting.
- Regenerative Drive Lift.
- Electric vehicle charging station.
- Air Handling Units (AHUs) and Fan Coil Units (FCUs) condensate water recycling system.
- Non-chemical anti-termite system.
- Air purification system to improve indoor air quality.



BCA  
**GREEN MARK FOR  
BUILDINGS AWARD**

**EduSports Building**  
New Non-Residential Buildings

**Client / Developer**  
National University  
of Singapore

**Architect**  
DP Architects Pte Ltd

**M&E Engineer**  
Beca Carter Hollings &  
Ferner (S.E.Asia) Pte Ltd

**Structural Engineer**  
Beca Carter Hollings &  
Ferner (S.E.Asia) Pte Ltd

**Quantity Surveyor**  
Rider Levett Bucknall  
Pte Ltd

**Main Contractor**  
Ando Singapore Pte Ltd

**Landscape Consultant**  
Sitetectonix Pte Ltd

**ESD Consultant**  
Arup Singapore Pte Ltd

**Key Features**

- Estimated energy savings: 1,859,308 kWh/yr; estimated water savings: 789 m<sup>3</sup>/yr; ETTV: 31.5 W/m<sup>2</sup>.
- Naturally ventilated semi-outdoor atrium.
- Extensive green roof.
- Waste management including provision of recycling facilities, recycling of e-waste and organic waste and implementation of biodegradable food packaging.
- High performance, self-cleaning façade with cool paint coating.
- UV emitters in AHUs to improve indoor air quality.
- Drought tolerant plants to reduce water consumption.
- Educational features including LCD display of energy/water consumption







BCA  
**GREEN MARK FOR  
BUILDINGS AWARD**

**Changi City**  
New Non-Residential Buildings



**Client / Developer**  
Ascendas Frasers Pte. Ltd.

**Project Manager**  
Ascendas Frasers Pte. Ltd.

**Architect**  
Aedas Pte. Ltd.

**M&E Engineer**  
Beca Carter Hollings & Ferner  
(S.E.Asia) Pte Ltd.

**Structural Engineers**  
Retail and Hotel:  
DE Consultants (S) Pte. Ltd.  
Business Park:  
AECOM Singapore Pte Ltd

**Quantity Surveyor**  
KPK Quantity Surveyors  
(Singapore) Pte Ltd

**Main Contractor**  
Nakano Singapore Pte. Ltd.

**Landscape Consultant**  
Belt Collins International  
(Singapore) Pte. Ltd.

**ESD Consultant**  
Arup Singapore Pte Ltd

**Key Features**

- Estimated energy savings: 15,050,221 kWh/yr; estimated water savings: 299,582 m<sup>3</sup>/yr; ETTV: 40.77 W/m<sup>2</sup>.
- Designation control system for lifts in office building.
- AHU installed with UVC emitter to improve indoor air quality.
- Skylight at retail atrium to provide natural daylight.
- Recycling of AHU condensate in office building and hotel.



BCA  
**GREEN MARK FOR  
BUILDINGS AWARD**

**Fusionopolis Phase 2A @ one-north**  
New Non-Residential Buildings

**Clients / Developers**  
JTC Corporation  
A\*STAR

**Project Manager**  
PM Link Pte Ltd

**Architect**  
P&T Consultants Pte Ltd

**M&E Engineer**  
Parsons Brinckerhoff Pte Ltd

**Structural Engineer**  
Arup Singapore Pte Ltd

**Quantity Surveyor**  
KPK Quantity Surveyors  
(Singapore) Pte Ltd

**Main Contractor**  
GS Engineering  
& Construction Corp

**Landscape Consultant**  
Martin Lee Designs

**ESD Consultant**  
Parsons Brinckerhoff Pte Ltd

**Key Features**

- Estimated energy savings: 14,839,226 kWh/yr; estimated water savings: 156,890 m<sup>3</sup>/yr; ETTV: 34.75 W/m<sup>2</sup>.
- Chiller plant system efficiency of 0.63kW/ton.
- Permanent measurement and verification instrumentation for the monitoring of chilled-water plant efficiency and heat balance.
- Low-e double glazing of vision panels.
- Integrated design of heat pipes for cooling coil at Modular Air Handling Units (MAHU) for efficient dehumidification and temperature control.
- Use of high performance fan filter units with low power consumption DC motors.
- Use of SGLS certified carpets, laminates, waterproofing system, external paint and dry-wall partitions. Timber decking, raised floor, ceiling panel made up of more than 30% of recycled content.



BCA  
**GREEN MARK FOR  
BUILDINGS AWARD**

**Mount Elizabeth Novena Hospital**

New Non-Residential Buildings



**Clients / Developers**  
Parkway Novena Pte Ltd  
Parkway Irrawaddy Pte Ltd

**Architect**  
Consultants Incorporated  
Architects + Planners

**Interior Design**  
HOK International  
(Singapore) Pte Ltd

**M&E Engineer**  
Parsons Brinckerhoff Pte Ltd

**Lighting Consultant**  
The Lightbox Pte Ltd

**Structural Engineer**  
T.Y.Lin International Pte Ltd

**Quantity Surveyor**  
Langdon & Seah  
Singapore Pte Ltd

**Main Contractor**  
Penta Ocean Construction Co.,  
Ltd

**Landscape Consultant**  
Mace Studio Pte Ltd

**TBP & ESD Consultant**  
ZEB-Technology Pte Ltd

**Key Features**

- Estimated energy savings: 13,176,532.28 kWh/yr; estimated water savings: 4,574.42 m<sup>3</sup>/yr; ETTV: 31.76 W/m<sup>2</sup>.
- Efficient chiller plant room design with an efficiency of 0.625 kW/ ton.
- Pre-cool AHU to improve indoor air quality, energy efficiency and Relative Humidity (RH) control.
- Demand control ventilation with carbon monoxide (CO) sensors for car park and carbon dioxide (CO<sub>2</sub>) sensors.
- Permanent instrumentation for measurement and verification of chiller plant.
- 10kWp onsite energy generation through photovoltaic panels.
- Energy efficient lighting design with LED and other efficient lighting systems.
- Lifts and escalators installed with Variable Voltage Variable Frequency (VVVF) motor and sensors.
- Extensive greenery at various levels.



BCA  
**GREEN MARK FOR BUILDINGS AWARD**

**National Heart Centre Singapore**  
New Non-Residential Buildings

**Client / Developer**  
Ministry of Health

**Project Manager**  
PM Link Pte Ltd

**Architect**  
ONG&ONG Pte Ltd

**M&E Engineer**  
Squire Mech Pte Ltd

**Structural Engineer**  
Beca Carter Hollings  
& Ferner (S.E.Asia) Pte Ltd

**Quantity Surveyor**  
Langdon & Seah  
Singapore Pte Ltd

**Main Contractor**  
Shimizu Corporation

**Landscape Consultant**  
ONG&ONG Pte Ltd

**Medical Planner**  
Broadway Malyan Asia Pte. Ltd.

**Façade Consultant**  
Arup Façade Engineering


**ESD Consultants**  
Lincolne Scott Ng Pte Ltd  
WSP Ng Pte Ltd

**Key Features**

- Estimated energy savings: 6,197,418 kWh/yr; estimated water savings: 12,534 m<sup>3</sup>/yr; ETTV: 36.4 W/m<sup>2</sup>.
- High performance building fabric.
- Chiller plant system efficiency of 0.607kW/ton with accurate permanent monitoring measurement and verification tools.
- Heat recovery.
- Rainwater harvesting.
- Recycling of AHUs Condensate.
- UVC emitters in all AHUs.
- Provision of charging stations for electric vehicles.



# Final Words




**IAQ & Energy Issues**




**Impact of ventilation and IAQ on  
occupant productivity and health**



**IAQ Audit – IAQ parameters, Ventilation  
parameters, Human Response**



**Relevant Standards**



**Energy Scenario**



**Integrated IAQ Energy Assessment**



**Thank You for your Attention**